

Table 1
Assumptions for revenue calculation

Capacity to bid into ELRP program	3.9 MW
Total number of events activated	10
Total number of hours of operation each event	4
Total annual hours activated	40
IESO Standby Payment	\$15/MWh
IESO Activation Payment	\$600/MWh
Incremental cost of operating generator	\$200/MWh
Net revenue sharing between Region& PowerStream	50/50

Table 2
Revenue calculation

Description	Revenue
Standby payment - 10 events x 2hrs/event x 3.9MW x \$15/MWh	\$1,170.00
Activation payment - 40 hours activated x 3.9MW x \$600/MWh	\$93,600.00
Cost of operation – 40 hours operation x 3.9MW x \$200/MWh	\$31,200.00
Net annual revenues = \$1,170 + \$93,600 - \$31,200	\$63,570
York Region share of net revenues at 50/50	\$31,785