

|                                                                                                |
|------------------------------------------------------------------------------------------------|
| <b>2006 REPORT OF THE GENERAL MANAGER</b>                                                      |
| <b>FIRE PROTECTION &amp; SAFETY<br/>LEGISLATIVE COMPLIANCE REPORT<br/>LTC FACILITY PROGRAM</b> |
| <b>LOCATION: MAPLE HEALTH CENTRE</b>                                                           |

Page 1 of 3

**STATUS REPORT RATING SCALE:**

1 = Full Compliance  
 2 = Partial Compliance  
 3 = Non-Compliance  
 4 = Not Applicable

| <b>STANDARDS<br/>REGULATION 17(1)</b>                                                                                                                                                                                                                                        | <b>COMPLIANCE<br/>STATUS</b> | <b>COMMENTS, ACTION TAKEN AND/OR<br/>FOLLOW-UP ACTIVITIES PLANNED</b>                                                                                                                                                                                                     |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| A) All fire hazards in the centre are eliminated. The centre is inspected at least once a year by an officer authorized to inspect buildings under the Fire Marshall's Act and the recommendations of the officer are carried out.                                           | 2                            | Annual Equipment Inspection: Jul 24/06.<br>Currently fully compliant, however, Annual Local Fire Department Inspection not completed until March 2007. No violations were reported or found. Inspection scheduling has been automated to prevent future issues or delays. |
| B) There is adequate protection from radiators or other heating equipment.                                                                                                                                                                                                   | 1                            | Full Compliance                                                                                                                                                                                                                                                           |
| C) The water supplies are adequate for all normal needs, including those of fire protection.                                                                                                                                                                                 | 1                            | Full Compliance                                                                                                                                                                                                                                                           |
| D) The fire protection equipment, including the sprinkler system, fire extinguishers, hose and stand pipe equipment are visually inspected at least once a month and serviced at least once a year.                                                                          | 1                            | Annual Service completed Jul 24/06.<br>Inspections: Jan 31; Feb 23; Mar 31; Apr 28; May 31; Jun 28; Jul 31; Aug 31, Sep 30; Oct 31; Nov 30; Dec 29/06.                                                                                                                    |
| E) The fire detection and alarm system is inspected at least once a year by qualified fire alarm maintenance personnel, and tested at least every month.                                                                                                                     | 1                            | Annual Inspection completed Jul 24/06.                                                                                                                                                                                                                                    |
| F) At least once a year the heating equipment is serviced by qualified personnel and the chimneys are inspected and cleaned if necessary.                                                                                                                                    | 1                            | Annual Inspection completed Jul 24/06.                                                                                                                                                                                                                                    |
| G) A written record is kept of each inspection and test of fire equipment, fire drill, the fire detection and alarm system, the heating system, chimneys and smoke detectors, and each record shall be retained for at least two years from the date of the inspection test. | 1                            | Records kept on file in Administrators and Maintenance offices for the period prescribed by the regulations.                                                                                                                                                              |
| H) The staff and residents are instructed in the method of sounding the fire detection and alarm system.                                                                                                                                                                     |                              | Fire Drills: Jan 24, 26 X2; Feb 21, 22, 23; Mar 21, 29, 30; Apr 26, 27, 28; May 29, 30, 31; Jun 20, 27X2; Jul 27X2, 31; Aug 22, 29 30; Sept 26, 27, 29; Oct 27X2, 31; Nov 29, 30X2; Dec 15, 29/06X2.                                                                      |
| I) The staff are trained in the proper use of the fire extinguishing equipment.                                                                                                                                                                                              | 1                            | Staff In-services: Feb 28; Mar 29; Apr 21; May 30, Jun 20; Aug 30; Sept 22; Oct 31; Nov 22; and Dec 5/06.                                                                                                                                                                 |
| J) A directive setting out the procedures that must be followed and the steps that must be taken by the staff and residents when a fire alarm is given is drawn up and posted in conspicuous places in the centre.                                                           | 1                            | Full Compliance: Fire alarm procedures developed in consultation with and approved by the Fire Department. Fire alarm procedures are posted throughout the Centre.                                                                                                        |

|                                                                                                |
|------------------------------------------------------------------------------------------------|
| <b>2006 REPORT OF THE GENERAL MANAGER</b>                                                      |
| <b>FIRE PROTECTION &amp; SAFETY<br/>LEGISLATIVE COMPLIANCE REPORT<br/>LTC FACILITY PROGRAM</b> |
| <b>LOCATION: MAPLE HEALTH CENTRE</b>                                                           |

**STATUS REPORT RATING SCALE:**

**1 = Full Compliance**

**2 = Partial Compliance**

**3 = Non-Compliance**

**4 = Not Applicable**

| <b>STANDARDS<br/>REGULATION 17(1)</b>                                                                                                                                                                                                            | <b>COMPLIANCE<br/>STATUS</b> | <b>COMMENTS, ACTION TAKEN AND/OR<br/>FOLLOW-UP ACTIVITIES PLANNED</b>                                                                                                                                                                                                                                                                         |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| K) The staff and residents are instructed in the procedures set out in the directive referred to in clause (j) and the procedures are practiced by staff and residents at least once a month using the fire alarm to initiate the drill.         | 1                            | Fire Drills: Jan 24, 26 X2; Feb 21, 22, 23; Mar 21, 29, 30; Apr 26, 27, 28; May 29, 30, 31; Jun 20, 27X2; Jul 27X2, 31; Aug 22, 29 30; Sept 26, 27, 29; Oct 27X2, 31; Nov 29, 30X2; Dec 15, 29/06X2.<br><br>Residents: Jan 18, 2006.<br>Staff In-services: Feb 28; Mar 29; Apr 21; May 30; Jun 20; Aug 30, Sept 22; Oct 31; Nov 22; Dec 5/06. |
| L) An inspection of the building, including the equipment in the kitchen and laundry, is made each night to ensure that there is no danger of fire and that all doors to stairwells, all fire doors and all smoke barrier doors are kept closed. | 1                            | Full Compliance: Inspections completed and documented on a daily basis.                                                                                                                                                                                                                                                                       |
| M) Adequate supervision is provided at all times for the security of the residents and the Centre.                                                                                                                                               | 1                            | Staffing levels meet or exceed MOHLTC guidelines.                                                                                                                                                                                                                                                                                             |
| N) Oxygen is not used or stored in the centre in a pressure vessel.                                                                                                                                                                              | 1                            | Full Compliance                                                                                                                                                                                                                                                                                                                               |
| O) Combustible rubbish is kept to a minimum. Inspection by qualified personnel and the chimneys inspected and cleaned if necessary.                                                                                                              | 1                            | Combustible rubbish is collected and removed on a regular basis.                                                                                                                                                                                                                                                                              |
| P) All exits are clear and unobstructed at all times.                                                                                                                                                                                            | 1                            | Full Compliance                                                                                                                                                                                                                                                                                                                               |
| Q) Combustible draperies, mattresses, carpeting, curtains, decorations and similar materials are suitably treated to render them resistant to the spread of flame and are retreated when necessary.                                              | 1                            | Purchasing specifications for all combustible furnishings require that materials be in accordance with the Ontario Fire Marshall's regulations governing the same.<br>Materials are retreated the same.                                                                                                                                       |
| R) Receptacles into which electric irons or other small appliances are plugged are equipped with pilot lights which glow when the appliance is plugged in.                                                                                       | 1                            | All small appliances are equipped with an automatic shut-off and appliance specific pilot lights.                                                                                                                                                                                                                                             |
| S) Lint traps in the laundry are cleaned out after each use of the equipment.                                                                                                                                                                    | 1                            | Lint traps are checked regularly and cleaned as required.                                                                                                                                                                                                                                                                                     |
| T) Flammable liquid and paint supplies are stored in suitable containers in non-combustible cabinets.                                                                                                                                            | 1                            | Full Compliance                                                                                                                                                                                                                                                                                                                               |
| U) Suitable non-combustible ashtrays are provided where smoking is permitted.                                                                                                                                                                    | 1                            | Ashtrays are made of non-combustible material.                                                                                                                                                                                                                                                                                                |

|                                                                                                |
|------------------------------------------------------------------------------------------------|
| <b>2006 REPORT OF THE GENERAL MANAGER</b>                                                      |
| <b>FIRE PROTECTION &amp; SAFETY<br/>LEGISLATIVE COMPLIANCE REPORT<br/>LTC FACILITY PROGRAM</b> |
| <b>LOCATION: MAPLE HEALTH CENTRE</b>                                                           |

Page 3 of 3

**STATUS REPORT RATING SCALE:**

**1 = Full Compliance**

**2 = Partial Compliance**

**3 = Non-Compliance**

**4 = Not Applicable**

| <b>STANDARDS<br/>REGULATION 17(1)</b>                                                                                                                                         | <b>COMPLIANCE<br/>STATUS</b> | <b>COMMENTS, ACTION TAKEN AND/OR<br/>FOLLOW-UP ACTIVITIES PLANNED</b>                                                                                        |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------|
| V) No portable electric heaters are issued in the centre that are not in accordance with standards of approval set down by the Canadian Standards Association.                | 1                            | LTC Facility purchasing policies require that all electrical equipment purchased and used in the centre must meet or exceed applicable CSA OR ULC standards. |
| W) No vaporizing liquid fire extinguishers are kept or used in centre.                                                                                                        | 1                            | Full Compliance                                                                                                                                              |
| X) No sprinkler heads, fire or smoke detector heads are painted or otherwise covered with any material or substance that is likely to prevent them from functioning normally. | 1                            | Full Compliance                                                                                                                                              |