

Emergency Power Review and Installation Schedule

Building Location	Special Considerations	Potential Improvements	Estimated Current Cost	Year	Status
2005 Work Plan					
37 North Street Town of Georgina (North View)	4 Storey	Battery enhancement to extend duration of emergency lighting in public areas.	\$2,000	2005	C
84 Oakridge Court Town of East Gwillimbury (Oxford Village)	3 ½ Storey	Battery enhancement to extend duration of lighting in public areas.	\$2,000	2005	C
474 Eagle Street Town of Newmarket (Fairy Lake Gardens)	Residents at 474 to use 468 Eagle Street as place of refuge. 4 Storey	Battery enhancement to extend duration of emergency lighting in public areas.	\$3,500	2005	C
55 Orchard Heights Town of Aurora (Orchard Heights Place)	2 Storey	Battery enhancement to extend duration of emergency lighting in public areas.	\$2,000	2005	C
48 Wilsen Road Township of King (Nobleview Pines)	No handicapped units 2 Storey	Battery enhancement to extend duration of emergency lighting to public areas	\$2,000	2005	C
90 Dew Street Township of King (Kingview Court)	No handicapped units 2 Storey	Battery enhancement to extend duration of emergency lighting to public areas.	\$2,000	2005	C
275 Woodbridge Ave. City of Vaughan (Woodbridge Manor)	No handicapped units 2 Storey	Battery enhancement to extend duration of emergency lighting in public areas.	\$,2000	2005	C

C denotes Complete
D denotes Developing Specifications

Building Location	Special Considerations	Potential Improvements	Estimated Current Cost	Year	Status
2006 Work Plan					
39 North Street Town of Georgina (North View Court)	39 North Street has large recreation room. Room to be used for residents of 37 & 39 North St. as place of refuge.	Battery enhancement for emergency lighting installation of hook up for portable generator operate corridor and stairwell lights as well as fire alarm system. Purchase of portable generator.	\$43,000	2006	C
325 Elm Road Town of Whitchurch-Stouffville (Elmwood Gardens)	3 Storey	Battery enhancement and installation of hook up for portable generator.	\$37,300	2006	C
190 Church Street Town of Georgina (Pineview Terrace)	4 Storey	Battery enhancement for emergency lighting. Installation of hook up for portable generator to operate corridor and stairwell lights as well as fire alarm system.. Purchase of portable generator.	\$35,700	2006	C
75 Dunlop Street Town of Richmond Hill (Evergreen Terrace)	4 Storey	Battery enhancement for emergency lighting. Installation of hook up for portable generator to operate corridor and stairwell lights as well as fire alarm system. Purchase of portable generator.	\$35,000	2006	C
57 Orchard Heights Town of Aurora (Orchard Heights Place)	6 Storey	Battery enhancement for emergency lighting.	\$2,500	2006	C

C denotes Complete
D denotes Developing Specifications

Building Location	Special Considerations	Potential Improvements	Estimated Current Cost	Year	Status
2007 Work Plan					
71 Dunlop Street Town of Richmond Hill (Maplewood Place)	Size and height of building 7 Storey	Expand power generation capacity to service one elevator.	\$230,000	2007	D
2008 Work Plan					
43 The Queensway North, Town of Georgina (Keswick Gardens)	Sewage Pumping Station ACL Client Centre and 25 ACL units Adult Day Care 3 ½ Storey	Fixed generator installation of sufficient size to operate emergency lighting, sewage pump, lighting in lounge, fire alarm system and ACL client centre, adult day centre and one elevator.	\$104,100	2008	
125 Pugsley Avenue Town of Richmond Hill (Rose Town)	Size and height of building handicap units on each floor 6 Storey	Installation of fixed generator of sufficient size to operate emergency lighting, outlets, and lights in lounge, fire panel, and one elevator.	\$151,000	2008	
349/351 Crowder Boulevard Town of Newmarket (Heritage East)	ACL Client Centre 25 ACL units Various additional units dedicated to special needs clients	Fixed generator installation of sufficient size to operate emergency lighting, and one elevator.	\$198,000	2008	
57 Orchard Heights Town of Aurora (Orchard Heights Place)	6 Storey	Connect fire panel and emergency lights to existing generator connection.	\$30,000	2008	

Building Location	Special Considerations	Potential Improvements	Estimated Current Cost	Year	Status
2009 Work Plan					
78 Dunlop Street Town of Richmond Hill (Dunlop Pines)	7 Storey	Expand existing generator capacity to service one elevator.	\$77,700	2009	
76 Dunlop Street Town of Richmond Hill (Dunlop Pines)	7 Storey	Expand generator capacity to service one elevator.	\$77,700	2009	
2010 Work Plan					
540 Timothy Street Town of Newmarket (Founders Place)	High Rise Design 9 Storey	Expand capacity of existing generator system to accommodate at least one elevator	\$25,500	2010	

Building Location	Special Considerations	Potential Improvements	Estimated Current Cost	Year
16105 Yonge Street Town of Aurora (Hadley Grange)	20 ACL units (in planning stage) 4 Storey	Emergency generator system in place	Nil	N/A
468 Eagle Street Town of Newmarket	High-rise design 13 Storey	Emergency generator system in place	Nil	N/A
Armitage Gardens Town of Newmarket	ACL Clients 3 Storey	Emergency generator system in place	Nil	N/A
Blue Willow City of Vaughan	4 Storey	Emergency generator system in place	Nil	N/A